

VOC Content Test Certificate

Thursday August 26th, 2010

Manufacturer: Construction Technologies Australia (P.O. Box 1135, Browns Plains B.C. QLD 4118)

Sample Description: Pro 2 Part

Date Tested: August 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Pro 2 Part
Architectural Sealant 250 grams per Litre as VOC content material	27 grams per Litre as VOC content per material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Pro 2 Part
Architectural Sealant 250 grams per Litre as VOC content material	27 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1008-21