

VOC Content Test Certificate

Friday April 18th, 2008

Manufacturer: Construction Technologies Australia Pty Ltd (70 Platinum Street, Crestmead Queensland 4132)

Sample Description: Ecopro ceramic tile adhesive

Date Tested: April 2008 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ecopro
Ceramic Tile Adhesive 65 grams per Litre material	12 grams per Litre material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ecopro
Ceramic Tile Adhesive 65 grams per Litre material	12 grams per Litre material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0804-18