

# VOC Content Test Certificate

Tuesday, 8<sup>th</sup> January 2013

Manufacturer: MCB Products Pty Ltd

70 Platinum Street

Crestmead Queensland 4132

Sample Description: Pro Premium ceramic tile adhesive

Date Tested: April 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

|  |                           |
|--|---------------------------|
| <b>Specification</b><br><br><b>Green Building Council of Australia</b><br><br><b>Green Star Office Design V2 IEQ-13</b><br><br><b>Green Star Office Design V3 IEQ-13</b><br><br><b>Green Star Office Interiors V1.1 IEQ-11</b> | <b>Pro Premium</b>        |
| Ceramic Tile Adhesive 65 grams per Litre   | <b>14 grams per Litre</b> |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0804-18\_V2