

VOC Content Test Certificate

Thursday February 12th, 2009

Manufacturer: MCB Products Pty Ltd (70 Platinum Street, Crestmead Queensland 4132)

Sample Description: A50 micro cement based mastic ceramic tile adhesive

Date Tested: February 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>A50</p>
Ceramic Tile Adhesive 65 grams per Litre	8 grams per Litre as VOC content per coating
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>A50</p>
Ceramic Tile Adhesive 65 grams per Litre	8 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0902-04