

# VOC Content Test Certificate

Friday June 20<sup>th</sup>, 2008

Manufacturer: MCB Products Pty Ltd

70 Platinum Street

Crestmead Queensland 4132

Sample Description: A74 micro-cement based mastic ceramic tile adhesive

Date Tested: June 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ-13</b>  <b>Green Star Office Design V3 IEQ-13</b>  <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>A74</b>
Ceramic Tile Adhesive 65 grams per Litre	<b>13 grams per Litre</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0806-19