

VOC Content Test Certificate

Friday April 18th, 2008

Manufacturer: MCB Products Pty Ltd

70 Platinum Street

Crestmead Queensland 4132

Sample Description: A80 ceramic tile adhesive

Date Tested: April 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Design V3 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	A80
Ceramic Tile Adhesive 65 grams per Litre	14 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0804-18