

VOC Content Test Certificate

Friday May 11th, 2012

Manufacturer: Construction Technologies Australia (70 Platinum St, Chestmead, QLD 4132)

Sample Description: A100 Adhesive

Date Tested: May 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	A100 Adhesive
Ceramic Tile Adhesive 65 grams per Litre as VOC content per material	4 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120429