

VOC Content Test Certificate

Wednesday, 22th April 2015

Supplier: Construction Technologies Australia Pty Ltd (2 Prime Drive, Seven Hills, NSW 2147)

Sample Description: AquaBlok Rapid waterproofing membrane

Date Tested: April 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p>Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>AquaBlok Rapid Waterproofing Membrane</p>
<p>Any solvent-based coating whose purpose is not covered in Table IEQ-13.1</p> <p>200 grams per Litre as VOC content per material</p>	<p><1 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BEng (Chemical Engineer)
Laboratory Technician

CV150331