

# VOC Content Test Certificate

Wednesday July 19<sup>th</sup>, 2017

Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park, NSW 2164)

Sample Description: Problend G15 Sanded Grout

Date Tested: April 2008 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia Green Star Design &amp; As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</b></p>	<p><b>Problend G15 Sanded Grout</b></p>
<p>General purpose adhesives and sealants: 50 grams per Litre material</p>	<p><b>12 grams per Litre material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dac Tuan Duong  
B E (Chem. Eng.)  
Consultant

CV170755