

VOC Content Test Certificate

Tuesday, 25th July 2017

Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park, NSW 2164).

Sample Description: Problend S1 Silicone

Date Tested: July 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	Problend S1 Silicone
General Purpose adhesives and Sealants: 50 grams per Litre as VOC content per material	46 gram per Litre as VOC content per material PASS
Architectural sealant: 250 grams per Litre as VOC content per material	46 gram per Litre as VOC content per material PASS



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV170765